

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140217-EX15327  
**Report Reference** EX15327-20080319  
**Issue Date** 2014-FEBRUARY-17

**Issued to:** SWASTIK PIPES LTD  
4 CENTRAL MARKET, WEST PUNJABI BAGH  
NEW DELHI DL 110026 INDIA


**This is to certify that  
representative samples of** METALLIC SPRINKLER PIPE  
See next page for models

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 852, Standard for Metallic Sprinkler Pipe For Fire  
Protection

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's  
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the  
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category  
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140217-EX15327  
**Report Reference** EX15327-20080319  
**Issue Date** 2014-FEBRUARY-17


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Schedule 40 (black or galvanized) steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, 10 and 12in. sizes.

Schedule 30 (black or galvanized) steel pipe in the 8, 10 and 12 in. sizes.

Schedule 20 (black or galvanized) steel pipe in the 8, 10 and 12 in. sizes.

Schedule 10 (black or galvanized) steel pipe in the 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, and 10 in sizes.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

